



A Century of Progress with Pride

March 4, 2016

Re: Request for Clarification (RFC)

Thank you for your interest in the Request for Qualifications (RFQ) currently posted for projects within the City of Berwyn. Questions have been presented on the RFQs and the following items should provide additional information on the project scopes:

- 19th Street watermain improvements – the existing 4” watermain shall be abandoned in place and replaced with an 8” watermain.
- Roadway improvements will consist of the removal and replacement of surface course and full depth replacement up to 20% of the roadway surface area.
- Sewers within projects limits shall be televised.
- Sewer modeling is not required.
- Survey is required for roadway, watermain and sewer improvements.
- Spot sidewalk improvements should be anticipated with any roadway improvement projects.
- No watermain or extensive sewer replacement is proposed for 36th Street.
- Lighting and sidewalk improvements city-wide will be on a removal and replace basis.
- Sidewalk locations will be determined by the City of Berwyn.
- Survey is not required for lighting and sidewalk improvements.
- Sidewalk improvements may include ADA improvements at intersections. All sidewalk improvements will be constructed following ADA, IDOT and city standards.
- Concrete QA/QC is required.

Feel free to contact me with questions.

Sincerely,

Robert Schiller, Public Works Director