



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19276, SPRINGFIELD, ILLINOIS 62794-9276 • (217) 782-2829

BRUCE RAUNER, GOVERNOR

LISA BONNETT, DIRECTOR

217/785-0561

February 3, 2016

KRISTOFER M. HASMAN
6700 WEST 30th STREET
BERWYN, IL 60402

Re: IL0310210, BERWYN - Notification of Reduced Lead/Copper Monitoring

Water System Official:

According to Agency records, your facility has just completed two consecutive six-month rounds of lead/copper monitoring without exceeding the action level. Therefore, your supply has been scheduled on a reduced triennial monitoring frequency. Your supply will be required to collect **30** lead/copper samples between June 1 and September 30, 2018. Sample sites for reduced monitoring must be chosen using the following criteria:

1. All Tier 1 sites (i.e., PIC..., P1A..., P1D...) sampled in the first two rounds of monitoring must be sampled before Tier 2 sites may be used. Likewise, all Tier 2 sites must be sampled before Tier 3 sites may be used.
2. Primary sites are preferred. However, previously approved alternates may be used if enough primary sites are not available.
3. **If your facility has lead service lines**, you should maintain the same mix of Tier Type P1A... and Tier Type PIC... that was sampled in the original sample pool. At no time should there be less than 50% Tier Type C, unless all the active Tier Type C sites are already included in the reduced monitoring sampling pool.
4. All Tier Type S must be sampled before Tier Type R may be sampled.

If sites are not chosen as outlined above, results will not be used to calculate compliance and your supply will receive a monitoring violation. The reduced sample sites should be identified on the enclosed form and submitted to this office as soon as possible.

Sincerely,

A handwritten signature in cursive script that reads "Jeri Long".

Jeri Long
Drinking Water Compliance Unit

cc: ROBERT SCHILLER
Enclosed: Reduced Site Plan Form